

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7161-0060:103 Page 1 of 1

CATEGORY: Cables-Fire Protective Signaling

LISTEE: Belden Wire & Cable Co., P.O. Box 1980, Richmond IN 47375-1980
Contact: Gerald Lee Dorna (765) 983-5200 Fax *(775) 805-2991

DESIGN: Type FPLR power-limited fire protective signaling cable. Refer to listee's data sheet for detailed product description and operational considerations.

Insulation: Semi-rigid PVC compound No. 70 through X79, X960 through X979, X2000 through X2049 or X-20 through X-39, X2400 through X2419, X-6501 through X-6539, or Geon 8891.

Shields: (Optional) metal or polyethylene terephthalate/metal tape shield.

Core Wrap: (Optional) Glass Reinforced TFE (Teflon) impregnated tape or polyethylene terephthalate.

Filler: (Optional) PVC or polypropylene.

Jacket: PVC Compound No. X-99000 through X-99199 or X-199000 through X-199199.

INSTALLATION: In accordance with listee's printed installation instructions, NEC Article 760, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type, classification and UL label.

APPROVAL: Listed as power-limited fire protective signaling cable.

*Rev. 03-20-06



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 28, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division